



# GUAM MEMORIAL HOSPITAL AUTHORITY

ATURIDÁT ESPETÁT MIMURIÁT GUÁHÅN

850 Governor Carlos Camacho Road, Tamuning, Guam 96913  
Operator: (671) 647-2330 or 2552 | Fax: (671) 649-5508



March 17, 2025

## AMENDMENT #12

GMHA Invitation for Bid No. 006-2025

for Removal and Replacement of GMHA's Mechanical System within the Operating Room's Surrounding Areas, including Air Handling Units (AHUs), Ductwork, Exhaust Fan System (EF) 1, 2, 3, 4, & 5, DDC System and Other Related Systems and Controls (Phase 2 Projects)

**This Amendment is in response to a request submitted by Johnson Controls, Inc:**

**Bid Submission:** In review of our scope of work, our engineers have found that fire dampers are not included in the mechanical drawings. In the past we have seen these as typically needed. To avoid change orders, we ask if fire dampers are required? And if so, who will install them? If we are, we recommend the design team to redraw the mechanical drawings

**Response:** Please refer to Plan Sheet M3.1 depicting a motorized damper as designed. Attached is a copy for your reference.

All others shall remain the same. Please acknowledge receipt of this amendment by signing and sending back to Materials Management via email to [materials.mgmt@gmha.org](mailto:materials.mgmt@gmha.org).

If you have any questions, please feel free to address your letter to Lillian Perez-Posadas MN, RN, via email to [materials.mgmt@gmha.org](mailto:materials.mgmt@gmha.org).

Sincerely;

DOLORES PANGELINAN  
Hospital Materials Management Administrator

ACKNOWLEDGMENT:

\_\_\_\_\_  
PRINT NAME

\_\_\_\_\_  
SIGNATURE

\_\_\_\_\_  
DATE

