



Guam Memorial Hospital Authority Aturidåt Espetåt Mimuriåt Guåhan



850 GOV. CARLOS CAMACHO ROAD
OKA, TAMUNING, GUAM 96913
TEL: 647-2444 or 647-2330
FAX: (671) 649-0145

June 11, 2019

AMENDMENT #1

GMHA IFB NO: 015 -2019: Removal & Replacement of Hospital Parking Lights

This amendment is issued to clarify inquiries from M.D. Crisostomo Company.

Vendor: I have inquired with Register Structural Engineer and he has concrete regarding existing foundation was this designed for the required 180 mph?

GMHA: The pedestal was constructed in 1988 and has withstand the 184 MPH wind velocity. Gust should have been greater than that. No sign of failure on the pedestal.

Vendor: On page 27, item #13 it read Delivery or completion date from issuance of purchase order (po) is Thirty (45) calendar days. Which one is the right?

GMHA: It is thirty days (30).

Vendor: Breakdown, page 28, Light Fixtures 3 each. There are 41 street light post with 2 each light fixtures?

GMHA: This is 3 each stock items of the light fixture to be turned over to GMHA after project is Completed.

Vendor: Their no one line diagram (electrical). Will the contractor responsibility is from the street light fixtures to existing power supply located above the existing foundation?

GMHA: Yes from exiting foundation to light fixture only.

Sincerely yours,

DOLORES F. PANGELINAN

Hospital Administrator Supply Management

ACKNOWLEDGMENT OF RECEIPT:

(Signature)

Print Name and Title

Date